

**ADDENDUM No. 27**

**CITY OF HIALEAH  
MILANDER AUDITORIUM  
4800 PALM AVENUE  
HIALEAH, FLORIDA**

**FEBRUARY 18, 2011**

TO ALL CONCERNED

The original Contract Documents for the Project entitled: **CITY OF HIALEAH – MILANDER AUDITORIUM – ELECTRICAL, BID NO. 2009/10-3230-00-093** is amended as noted in this Addendum No. 27.

This Addendum No. 27 consists of 1 Typed Pages, 0 Sketches 0 Attachment and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue: \_\_\_\_\_

Jorge Guanchez – Director

Date: February 18, 2011

ACKNOWLEDGEMENT

Receipt of this Addendum No. 27 shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 687-2642 and submitted with sealed bids.

CLARIFICATIONS:

1. Contractor needs to provide a duplex outlet (non-GFI), on a dedicated circuit, inside the elevator pit.
2. Contractor needs to provide, a 1” underground PVC pipe from panel PP1, to the base of the “Milander Park” sign, terminating on pull-box. For exact location of sign, please refer to sheet AS-1.1. Sign is next to Palm Ave, East on main entrance and it is labeled as “existing sign to remain”.

**ADDENDUM RECEIPT FORM**

**CITY OF HIALEAH  
MILANDER AUDITORIUM  
ELECTRICAL**

**CONTRACTOR'S NAME** \_\_\_\_\_

**ADDRESS** \_\_\_\_\_

**PHONE NO.** \_\_\_\_\_ **FAX NO.** \_\_\_\_\_

**CONTACT NAME** \_\_\_\_\_ **E-MAIL** \_\_\_\_\_

**THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY OF HIALEAH @ (305) 687-2642**

**ADDENDUM**

**SIGNATURE**

**DATE**

\_\_\_\_\_  
27

**ARF**